Certificate of Test

Quote No.: NC7900 REPORT No.: FNC12089

COMBUSTIBILITY TEST FOR MATERIALS IN ACCORDANCE WITH AS 1530.1-1994

TRADE NAME: Paroc Stonewool / Rockwool

SPONSOR: Flavell Management & Industrial Services Pty Ltd

19-21 Bromley Road EMU PLAINS NSW 2750

AUSTRALIA

DESCRIPTION OF

TEST SAMPLE: The sponsor described the tested specimen as a rockwool insulation.

Nominal thickness: 50 mm

Nominal density: 80 kg/m³

Colour: green / brown

TEST PROCEDURE: Five (5) samples were tested in accordance with Australian Standard 1530

Methods for fire tests on building materials, components and structures, Part 1-

1994: Combustibility Test for Materials.

An alternative suitable insulating material was used to fill the annular space

between the furnace tubes, as specified in Clause 4.2 of ISO 1182:2010.

DESIGNATION: The material is NOT deemed COMBUSTIBLE according to the test criteria specified

in Clause 3.4 of AS 1530.1-1994.

These test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

DATE OF TEST: 03 January 2018

Issued on the 5th day of January 2018 without alterations or additions.

Faustin Molina Brett Roddy

Testing Officer Team Leader, Fire Testing and Assessments

Copyright CSIRO 2018 ©. Copying or alteration of this report without written authorisation from CSIRO is forbidden.



NATA Accredited Laboratory Number: 165 Corporate Site No 3625

Accredited for compliance with ISO/IEC 17025 - Testing.

CSIRO INFRASTRUCTURE TECHNOLOGIES

