

Emission Test Certificate

Thursday October 23rd, 2008

Supplier: F M Insulation

Unit 6, 10 Bromley Road

Emu Plains NSW 2750

Product Description: Therm-o-lag PE spi

Date Tested: October 2008

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Therm-o-lag PE spi	
Total Volatile Organic Compounds	<0.05 mg/m ² /hr (24 hours) The result was below the detection limit for the method and indicates that the emissions can be considered insignificant.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV081010