

# Emission Test Certificate

Wednesday November 19<sup>th</sup>, 2008

Supplier: F M Insulation

Unit 6, 10 Bromley Road

Emu Plains NSW 2750

Product Description: Therm-o-lag Roxul (Foil Faced Rockwool Blanket)

Date Tested: November 2008

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

| Therm-o-lag Roxul |                                       |
|-------------------|---------------------------------------|
| Formaldehyde      | 0.02 mg/m <sup>2</sup> /hr (24 hours) |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV081033